ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಇಂಜಿನಿಯರ್ರವರ ಕಛೇರಿ, ನಂ.1,ಲೋಕೋಪಯೋಗಿ ಇಲಾಖೆ ಉಪವಿಭಾಗ, ಹಾಸನ. ಲೋಕೋಪಯೋಗಿ ಭವನ, ಆರ್.ಸಿ. ರಸ್ತೆ ಹಾಸನ. email: pwdhsnsubdvn1@gmall.com

ಸಂ.1/ಸಕಾಇಂ/ಲೋಇಉವಿ/ಹಾಸನ/ಶಾಲಾ ಸುರಕ್ಷತಾ ಪತ್ರ/2022-23/ ನಿರಿ

ರವರಿಗೆ,

11-07-2022

ಪ್ರಾಂಶುಪಾಲರು, ಕ್ರೈಸ್ಟ್ ಸ್ಕೂಲ್ ವಿದ್ಯಾನಗರ, ಹಾಸನ.

ಮಾನ್ಯರೆ,

<u>ವಿಷಯ</u> :- ಕ್ರೈಸ್ಸ್ ಸ್ಕೂಲ್, ವಿದ್ಯಾನಗರ, ಹಾಸನ ಬ್ಲಾಕ್-। ಕಟ್ಟಡದ ಸುರಕ್ಷತಾ ಪ್ರಮಾಣ ಪತ್ರ ಪಡೆಯುವ ಬಗ್ಗೆ (Building Safety Certificate)

<u>ಉಲ್ಲೇಖ</u>:-l) Principal, Christ School, Vidyanagar, Hassan Ltr. dt:.09.03.2022.

2) ಸರ್ಕಾರದ ಅಪರ ಕಾರ್ಯದರ್ಶಿ, ಲೋಕೋಪಯೋಗಿ ಇಲಾಖೆ, ಬೆಂಗಳೂರು ಇವರ ಪತ್ರ ಸಂ:ಲೋಇ 59/ಬಿಇಡಿ 2019/ದಿನಾಂಕ 07.05.2022.

ಮೇಲ್ಕಂಡ ವಿಷಯಕ್ಕೆ ಸಂಬಂಧಿಸಿದಂತೆ, ಕ್ರೈಸ್ಟ್ ಸ್ಕೂಲ್, ವಿದ್ಯಾನಗರ, ಹಾಸನ ರವರ ಶಾಲಾ ಕಟ್ಟಡದ ಸುರಕ್ಷತೆ ಮತ್ತು ಭದ್ರತೆ ಬಗ್ಗೆ ಪರಿಶೀಲಿಸಿ (Building Safety Certificate) ದೃಢೀಕರಣ ಪತ್ರವನ್ನು ನೀಡುವಂತೆ ಉಲ್ಲೇಖಿತ (1) ರ ಪತ್ರದಲ್ಲಿ ಕೋರಿರುತ್ತೀರಿ. ಅದರಂತೆ ಸದರಿ ಶಾಲಾ ಕಟ್ಟಡಕ್ಕೆ ಸಂಬಂಧಿಸಿದಂತೆ ಮಾರಕವಾದ ದಾಖಲೆಗಳನ್ನು ಪಡೆದು ಪರಿಶೀಲಿಸಿದ್ದು ಕಟ್ಟಡವನ್ನು ಈ ಉಪವಿಭಾಗದ ತಾಂತ್ರಿಕೆ ಸಿಬ್ಬಂದಿಯವರೊಂದಿಗೆ ದಿನಾಂಕ 20.06.2022 ರಂದು ಪರಿಶೀಲಿಸಲಾಗಿ ಸದರಿ ನಿವೇಶನದಲ್ಲಿ ಬ್ಲಾಕ್-। ಕಟ್ಟಡವನ್ನು 2008 ರಲ್ಲಿ ನಿರ್ಮಿಸಲಾಗಿದೆ. ಕಟ್ಟಡವನ್ನು ಪರಿವೀಕ್ಷಿಸಲಾಗಿ ಯಾವುದೇ ರೀತಿಯ ಬಿರುಕುಗಳು ಕಂಡು ಬಂದಿಲ್ಲವಾಗಿದ್ದು ಕಟ್ಟಡವು ಮೇಲ್ನೋಟಕ್ಕೆ ಸುರಕ್ಷಿತವಾಗಿದೆ ಎಂದು ಈ ಮೂಲಕ ತಿಳಿಸಲಾಗಿದೆ. ಹಾಗೂ ಕಟ್ಟಡಗಳನ್ನು ನಿಯತಕಾಲಿಕವಾಗಿ ನಿರ್ವಹಣೆ ಹಾಗೂ ದುರಸ್ಥಿಗೊಳಿಸಲು ಸೂಚಿಸಲಾಗಿದೆ.

ಅದಕ:

1) ಅರ್ಜಿಯ ಪ್ರತಿ

2) ಎನ್.ಡಿ.ಟಿ. ಟೆಸ್ಟ್ ಗಳ ಫಲಿತಾಂಶಗಳ ಪ್ರತಿ

ತಮ್ಮ ವಿಶ್ವಾಸಿ,

ಸಹಾಯಕ ಹಾಯ್ ಪಾಲಕ ಇಂಜಿನಿಯರ್. ನಂ.1, ಲೋಕೋಪಯೋಗಿ ಇಲಾಖೆ,

ಹಾಸನ.

# Format for Application to be submitted by the Edcational Organizations

1	Name and address of the building	CHRIST SCHOOL HASSAN, (St. Thomas Education Society (Reg.)) Vidyanagar, Hassan				
2	Number of stories approved in the sanction building plan	Block I G.F. + 3 Floors,				
3	Year of Construction	2008 Block				
	Submission of Following documents are not mandatory for the building already constructed and working. But mandatory for new buildings					
4	Submission of Following documents ar constructed and working. Bu	re not mandatory for the building already it mandatory for new buildings				
4 a)	Submission of Following documents are constructed and working. But Approved building plan from the competent authority	re not mandatory for the building already it mandatory for new buildings  Enclosed				

Date: 7/7/2029

Place: Hassan

(Seal and Signature of the Dingsipation) Christ School

Remarks of the Inspecting Authority Idyanagar, Hassan-573 201

ಕ್ರೈಸ್ಟ್ ಸ್ಕೂಲ್. ವಿದ್ಯಾನಗರ, ಹಾಸನ ರವರು ಸಲ್ಲಿಸಿರುವ ಪೂರಕವಾದ ದಾಖಲೆಗಳನ್ನು ಪಡೆದು ಪರಿಶೀಲಿಸಿದ್ದು ಕಟ್ಟಡವನ್ನು ಈ ಉಪವಿಭಾಗದ ತಾಂತ್ರಿಕ ಸಿಬ್ಬಂದಿಯವರೊಂದಿಗೆ ದಿನಾಂಕ 20.06.2022 ರಂದು ಪರಿಶೀಲಿಸಲಾಗಿ ಸದರಿ ಸಂಸ್ಥೆಯ ಆವರಣದಲ್ಲಿ ಬ್ಲಾಕ್-1 ಕಟ್ಟಡವನ್ನು 2008 ರಲ್ಲಿ ನಿರ್ಮಿಸಲಾಗಿದೆ. ಸದರಿ ಕಟ್ಟಡವನ್ನು ಪರಿವೀಕ್ಷಿಸಲಾಗಿ ಯಾವುದೇ ರೀತಿಯ ಬಿರುಕುಗಳು ಕಂಡು ಬಂದಿರುವುದಿಲ್ಲ. ಕಟ್ಟಡವು ಮೇಲ್ನೋಟಕ್ಕೆ ಸುರಕ್ಷಿತವಾಗಿದೆ ಎಂದು ಅಭಿಪ್ರಾಯಪಡಲಾಗಿದೆ. ಹಾಗೂ ಕಟ್ಟಡವನ್ನು ನಿಯತಕಾಲಿಕವಾಗಿ ನಿರ್ವಹಣೆ ಹಾಗೂ ದುರಸ್ಥಿಗೊಳಿಸಲು ಸೂಚಿಸಲಾಗಿದೆ.

Shangkacken

(Seal and Signature of the Authority)
Assistant Executive Engineer
No.1, Public Works, Ports and
Inland Water Transport Department
Sub-Division, Hassan



ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಇಂಜಿನಿಯರ್ರವರ ಕಛೇರಿ, ನಂ.l.ಲೋಕೋಪಯೋಗಿ ಇಲಾಖೆ ಉಪವಿಭಾಗ, ಹಾಸನ. ಲೋಕೋಪಯೋಗಿ ಭವನ, ಆರ್.ಸಿ. ರಸ್ತೆ. ಹಾಸನ. email: pwdhsnsubdvn1@gmail.com

ಸಂ.।/ಸಕಾಇಂ/ಲೋಇಉವಿ/ಹಾಸನ/ಶಾಲಾ ಸುರಕ್ಷತಾ ಪತ್ರ/2022-23/ ನಿಂನಿ

ರವರಿಗೆ.

11-07-2022

ಪ್ರಾಂಶುಪಾಲರು, ಕ್ರೈಸ್ಟ್ ಸ್ಕೂಲ್ ವಿದ್ಯಾನಗರ, <u>ಹಾಸನ</u>.

ಮಾನ್ಯರೆ,

<u>ವಿಷಯ</u> :- ಕ್ರೈಸ್ಟ್ ಸ್ಕೂಲ್, ವಿದ್ಯಾನಗರ, ಹಾಸನ ಬ್ಲಾಕ್-2 ಕಟ್ಟಡದ ಸುರಕ್ಷತಾ ಪ್ರಮಾಣ ಪತ್ರ ಪಡೆಯುವ ಬಗ್ಗೆ (Building Safety Certificate)

<u>ಉಲ್ಲೇಖ</u>:-1) Principal, Christ School, Vidyanagar, Hassan Ltr. dt:.09.03.2022.

2) ಸರ್ಕಾರದ ಅಪರ ಕಾರ್ಯದರ್ಶಿ, ಲೋಕೋಪಯೋಗಿ ಇಲಾಖೆ, ಬೆಂಗಳೂರು ಇವರ ಪತ್ರ ಸಂ:ಲೋಇ 59/ಬಇಡಿ 2019/ದಿನಾಂಕ 07.05.2022.

ಮೇಲ್ಕಂಡ ವಿಷಯಕ್ಕೆ ಸಂಬಂಧಿಸಿದಂತೆ, ಕ್ರೈಸ್ಟ್ ಸ್ಕೂಲ್, ವಿದ್ಯಾನಗರ, ಹಾಸನ ರವರ ಶಾಲಾ ಕಟ್ಟಡದ ಸುರಕ್ಷತೆ ಮತ್ತು ಛದ್ರತೆ ಬಗ್ಗೆ ಪರಿಶೀಲಿಸಿ (Building Safety Certificate) ದೃಢೀಕರಣ ಪತ್ರವನ್ನು ನೀಡುವಂತೆ ಉಲ್ಲೇಖಿತ (1) ರ ಪತ್ರದಲ್ಲಿ ಕೋರಿರುತ್ತೀರಿ. ಅದರಂತೆ ಸದರಿ ಶಾಲಾ ಕಟ್ಟಡಕ್ಕೆ ಸಂಬಂಧಿಸಿದಂತೆ ಮೂರಕವಾದ ದಾಖಲೆಗಳನ್ನು ಪಡೆದು ಪರಿಶೀಲಿಸಿದ್ದು ಕಟ್ಟಡವನ್ನು ಈ ಉಪವಿಭಾಗದ ತಾಂತ್ರಿಕೆ ಸಿಬ್ಬಂದಿಯವರೊಂದಿಗೆ ದಿನಾಂಕ 20.06.2022 ರಂದು ಪರಿಶೀಲಿಸಲಾಗಿ ಸದರಿ ನಿವೇಶನದಲ್ಲಿ ಬ್ಲಾಕ್-2 ಕಟ್ಟಡವನ್ನು 2011 ರಲ್ಲಿ ನಿರ್ಮಿಸಲಾಗಿದೆ. ಕಟ್ಟಡವನ್ನು ಪರಿವೀಕ್ಷಿಸಲಾಗಿ ಯಾವುದೇ ರೀತಿಯ ಬರುಕುಗಳು ಕಂಡು ಬಂದಿಲ್ಲವಾಗಿದ್ದು ಕಟ್ಟಡವು ಮೇಲ್ನೋಟಕ್ಕೆ ಸುರಕ್ಷಿತವಾಗಿದೆ ಎಂದು ಈ ಮೂಲಕ ತಿಳಿಸಲಾಗಿದೆ. ಹಾಗೂ ಕಟ್ಟಡಗಳನ್ನು ನಿಯತಕಾಲಿಕವಾಗಿ ನಿರ್ವಹಣೆ ಹಾಗೂ ದುರಸ್ಥಿಗೊಳಿಸಲು ಸೂಚಿಸಲಾಗಿದೆ.

ಅಡಕ:

1) ಅರ್ಜಿಯ ಪ್ರತಿ

2) ಎನ್.ಡಿ.ಟಿ. ಟೆಸ್ಟ್ಗಳ ಫಲಿತಾಂಶಗಳ ಪ್ರತಿ

ತಮ್ಮ ವಿಶ್ವಾಸಿ,

ಸಹಾಯಕ ಕಾರ್ಯವಾರ್ ಸಂಜನೆಯರ್. ನಂ.1, ಲೋರ್ಕಾಪಯೋಗಿ ಇಲಾಖೆ, ಹಾಸನ.

# Format for Application to be submitted by the Edcational Organizations

Name and address of the building	CHRIST SCHOOL HASSAN, (St. Thomas Education Society (Reg.)) Vidyanagar, Hassan			
Number of stories approved in the sanction building plan	Block II G.F. + 3 Floors,			
Year of Construction	II 2011			
Submission of Following documents are not mandatory for the building already constructed and working. But mandatory for new buildings				
Approved building plan from the competent authority	Enclosed			
Completion certificate duly signed by the supervision Engineer who is in charge of the building	Enclosed			
	Number of stories approved in the sanction building plan  Year of Construction  Submission of Following documents ar constructed and working. But Approved building plan from the competent authority  Completion certificate duly signed by the supervision Engineer who is in charge of the			

Date: 7/7/2022

Place: Hassan

(Seal and Sobature of the imgipulation)
Christ School

Remarks of the Inspecting Authoritydyanagar, Hassan-573 201

ತ್ರೈಸ್ಟ್ ಸ್ಕೂಲ್, ವಿದ್ಯಾನಗರ, ಹಾಸನ ರವರು ಸಲ್ಲಿಸಿರುವ ಪೂರಕವಾದ ದಾಖಲೆಗಳನ್ನು ಪಡೆದು ಪರಿಶೀಲಿಸಿದ್ದು ಕಟ್ಟಡವನ್ನು ಈ ಉಪವಿಭಾಗದ ಕಾಂತ್ರಿಕ ಸಿಬ್ಬಂದಿಯವರೊಂದಿಗೆ ದಿನಾಂಕ 20.06.2022 ರಂದು ಪರಿಶೀಲಿಸಲಾಗಿ ಸದರಿ ಸಂಸ್ಥೆಯ ಆವರಣದಲ್ಲಿ ಬ್ಲಾಕ್. 11 ಕಟ್ಟಡವನ್ನು 2011 ರಲ್ಲಿ ನಿರ್ಮಿಸಲಾಗಿದೆ. ಸದರಿ ಕಟ್ಟಡದ ಒಂದು ಭಾಗದಲ್ಲಿ ಮಾತ್ರ ಮೆಟ್ಟಿಲು ಗಳಿದ್ದು ತುರ್ತು ಸಂಧರ್ಭಗಳಿಲ್ಲಿ ಉಪಯೋಗಕ್ಕಾಗಿ ಹಾಗೂ ಸುರಕ್ಷತಾ ದೃಷ್ಠಿಯಿಂದ ಮತ್ತೊಂದು ಭಾಗದಲ್ಲೂ ಮೆಟ್ಟಿಲುಗಳನ್ನು ನಿರ್ಮಿಸಲು ಸೂಚಿಸಲಾಗಿದೆ. ಸದರಿ ಕಟ್ಟಡವನ್ನು ಪರಿವೀಕ್ಷಿಸಲಾಗಿ ಕಟ್ಟಡದಲ್ಲಿ ಯಾವುದೇ ರೀತಿಯ ಬರುಕುಗಳು ಕಂಡು ಬಂದಿರುವುದಿಲ್ಲ. ಕಟ್ಟಡವು ಮೇಲ್ನೋಟಕ್ಕೆ ಸುರಕ್ಷಿತವಾಗಿದೆ ಎಂದು ಅಭಿಪ್ರಾಯಪಡಲಾಗಿದೆ. ಹಾಗೂ ಕಟ್ಟಡವನ್ನು ನಿಯತಕಾಲಿಕವಾಗಿ ನಿರ್ವಹಣೆ ಹಾಗೂ ದುರಸ್ಥಿಗೊಳಿಸಲು ಸೂಚಿಸಲಾಗಿದೆ.

Dhampeoky

(Seal and Signature of the Authority)

Assistant Executive Engineer
No.1, Public Works, Ports and
Inland Water Transport Department
Sub-Division, Hassan



### INDIA NON JUDICIAL

### Government of Karnataka

Rs. 20

#### e-Stamp

Certificate No.

Certificate Issued Date

Account Reference

Unique Doc. Reference

Purchased by

Description of Document

Description

Consideration Price (Rs.)

First Party

Second Party

Stamp Duty Paid By

Stamp Duty Amount(Rs.)

IN-KA96728738509828V

: 19-Jun-2023 01:24 PM

: NONACC (FI)/ kaksfcl08/ HASSAN/ KA-HS

: SUBIN-KAKAKSFCL0872370788584976V

: CHRIST SCHOOL HASSAN

: Article 4 Affidavit

: AFFIDAVIT

: 0 (Zero)


CHRIST SCHOOL HASSAN


CHRIST SCHOOL HASSAN


(Twenty only)

सत्यमव जयत

For Sahana Multipurpose Souhardha Co-operative Ltd, (R)







Please write or type below this line -



- The authenticity of this Stamp certificate should be verified at 'www.sholleatamp.com' or using e-Stamp Mobile Any discrepancy in the details on this Certificate and as available on the website / Mobile App renders it invalid The onus of checking the legitimacy is on the users of the certificate.
- In case of any discrepancy please inform the Competent Authority.

## FORMAT FOR APPLICATION TO BE SUBMITTED BY THE EDUCATIONAL ORGANSIATIONS

1	Name and Address of the Building	Christ School, Hassan(St Thomas Education Society(Reg.)) Vidhyanagar, Hassan Block-I G.F + 3 Floors		
2	No of Stares Approved in the Sanction Building Plan			
3	Year of Construction	2008	Block-1	
4	Submission of following Documents is Not Mandatory for the Building Already Constructed and Working. But Mandatory for New Buildings			
a)	Approve Building Plan From the Competent Authority	En	closed	
b)	Completion Certificate duly Signed by the Supervision Engineer who is in charge of	Enclosed		

Date: 07,07,2022 Place: Hassan

Principal

### Remarks of the Inspecting Authority

By verifying all the concerned documents of the Buildings submitted by the Christ School Vidhyanagar, Hassan, the technical Staff of the Hassan subdivision visited on 20.06.2022 and inspected the Block-1 building of school premises which was built on 2008 and they opined that the building is safe and free from cracks and also instructed to maintain the building properly from time to time

Sd/Assistant Executive Engineer
No.1 Public works,ports and
Inland Water Transport department
Sub-division Hassan

It is hereby declared that all the paragraphs are translated from Kannada to English are true and correct to best of my Knowledge and Belief and I swear accordingly

S, SP RENUKAPRASAD HASSAN Reg.No 139/LCL 2005 Rnxd, LAW-L CL/59/2020 Expry on:04-01-2026 "NOTARY"

NO. OF CORRECTIONS

Notary, Hassan

Signed and sworn to before me In 19-06.3 at Hassan

Motary Public Hanna



### INDIA NON JUDICIAL

### Government of Karnataka

### e-Stamp

Certificate No.

Certificate Issued Date

Account Reference

Unique Doc. Reference

Purchased by

Description of Document

Description

Consideration Price (Rs.)

First Party

Second Party

Stamp Duty Paid By

Stamp Duty Amount(Rs.)

IN-KA96731759745332V

: 19-Jun-2023 01:25 PM

: NONACC (FI)/ kaksfcl08/ HASSAN/ KA-HS

: SUBIN-KAKAKSFCL0872376972411241V

: CHRIST SCHOOL HASSAN

Article 4 Affidavit

**AFFIDAVIT** 

: 0

(Zero)

: CHRIST SCHOOL HASSAN


: CHRIST SCHOOL HASSAN

: 20

(Twenty only)

For Sahana Multipurpose सत्यमव जयत Souhardha Co-operative Ltd, (R)







Please write or type below this line .......





- The crus of checking the legitimacy is on the usors of the certificate. 3 In case of any discrepancy please inform the Compelent Authority.

### FORMAT FOR APPLICATION TO BE SUBMITTED BY THE EDUCATIONAL ORGANSIATIONS

1	Name and Address of the Building	Christ School, Hassan(St Thomas Education Society(Reg.)) Vidhyanagar, Hassan Block-II G.F + 3 Floors		
2	No of Stares Approved in the Sanction Building Plan			
3	Year of Construction	2011	Block-II	
4	Submission of following Documents is Not Mandatory for the Building Already Constructed and Working. But Mandatory for New Buildings			
a)	Approve Building Plan From the Competent Authority	Enclosed		
b)	Completion Certificate duly Signed by the Supervision Engineer who is in charge of	Enc	Enclosed	

Date: 07.07.2022

Place: Hassan

Principal

Remarks of the Inspecting Authority

By verifying all the concerned documents of the Buildings submitted by the Christ School Vidhyanagar, Hassan, the technical Staff of the Hassan subdivision visited on 20.06.2022 and inspected the Block-II building of school premises which was built on 2011 and they opined that the building is safe and free from cracks. However the building is having only one side staircase so they instructed to build one more staircase on the other side of the building to use in emergency purpose and also instructed to maintain the building properly from time to time

Sd/-

Assistant Executive Engineer
No.1 Public works,ports and
Inland Water Transport department
Sub-division Hassan

Republication of the paragraphs are translated from Kannada to English are true and correct to the best of my Knowledge and Belief and I swear support and sworn to before me

NO. OF CORRECTIONS

Notary, Hassan

Notary Public Hassar

In 1906, 27 at Hassan